



SUMMARY TEST DATA ON DTA-2G18G-60-12-CD-1-20DBM-TS

Customer: _____
 Job No: _____
 Model No: DTA-2G18G-60-12-CD-1-20DBM-TS
 Serial No: PL24013/1850

Tested By: K. Mansfield
 Date: Thursday, December 13, 2018
 Temperature: +25° C
 Drawing No: 27617795 Rev: A2

TEST. ITEM NO	PARAMETERS	SPECIFIED VALUE	PASS/FAIL	QA QC	
1	Frequency Range:	2 GHz – 18 GHz	2 GHz – 18 GHz	PMI QA 1	
2	Insertion Loss:	4.8 dB Max.	4.2 dB See Plot		
3	VSWR:	2.0:1 Max.	1.65:1 See Plot		
4	Flatness to 20 dB:	± 1.0 dB Typ.	0.64 dB See Plot		
6	Flatness to 40 dB:	± 1.25 dB Typ.	0.7 dB See Plot		
7	Flatness to 60 dB:	± 3.0 dB Typ.	1.19 dB See Plot		
8	Accuracy of Attenuation 0 to 20 dB:	± 1.0 dB Typ.	0.11 dB See Plot		
9	Accuracy of Attenuation 20 to 40 dB:	± 1.5 dB Typ.	0.1 dB See Plot		
10	Accuracy of Attenuation 40 to 60 dB:	± 2.0 dB Typ.	0.07 dB See Plot		
11	Temp. Sensor:	10mV/°C, 3.0V @ 25°C	3V		
12	Switching Speed:	On Time: 1.0 µs Max. Off Time: 0.5 µs Max.	<1.0 µs On Time <0.5 µs Off Time See Typical Characteristics		
13	DC Supply:	+15VDC @ 150 mA Max.	119 mA		PMI QA 1

Programed Attenuation	Attenuation	Accuracy of Attenuation	Flatness dB
dB	dB	dB	±dB
0.0156	0.0389	-0.02	0.01
0.0313	0.0585	-0.03	0.01
0.0625	0.09	-0.02	0.02
0.125	0.14	-0.02	0.03
0.25	0.26	-0.01	0.04
0.50	0.50	0.00	0.05
1.00	1.00	0.00	0.08
2.00	2.00	0.00	0.11
4.00	3.99	0.01	0.20
8.00	7.99	0.01	0.37
16.00	15.97	0.01	0.59
32.00	31.99	0.01	0.70

Programed Attenuation	Attenuation	Accuracy of Attenuation	Flatness dB
dB	dB	dB	±dB
5.00	4.89	0.11	0.24
10.00	9.98	0.02	0.44
15.00	14.92	0.08	0.57
20.00	19.96	0.04	0.64
25.00	24.94	0.06	0.69
30.00	29.96	0.04	0.70
35.00	34.90	0.10	0.70
40.00	39.94	0.06	0.67
45.00	44.95	0.05	0.64
50.00	49.99	0.01	0.56
55.00	54.93	0.07	0.87
60.00	59.96	0.04	1.19

QA/QC Approval:



PMI
QA 1

Date: 12/13/18



SUMMARY TEST DATA ON DTA-2G18G-60-12-CD-1-20DBM-TS

PL24013/1850





**SUMMARY TEST DATA
ON
DTA-2G18G-60-12-CD-1-20DBM-TS**

PL24013/1850

