

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	--	Original Release	21 Jan 2008	PRELIMINARY

REV STATUS	REV	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SHEETS	SHEET	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16

REV STATUS	REV																
SHEETS	SHEET	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32

SCD No.: MIKES 730049			<p align="center"><b>Planar Monolithics Industries, Inc.</b> 7311-G Grove Road, Frederick, MD 21704</p>														
		DATE 21 Jan 2008															
DRAWN	S Kuhn		<p align="center"><b>ACCEPTANCE TEST PROCEDURE</b> MODEL: RFFD-618-730049 PART No. T0737SOCN730049-001 FILTER DETECTOR</p>														
CHECK																	
APPD.																	
ENGR.																	
QC.																	
			SIZE: A	FSCM: 0ZXZ8	DRAWING No: 140-R000-000												
			REV: A	SCALE: N/A	SHEET <u>1</u> OF <u>12</u>												



**DRAWING No: 140-R000-000**

**PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029**

**URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:**

**ISO 9001:2000 CERTIFIED**

---

**ACCEPTANCE**

**TEST PROCEDURE**  
**(ATP)**

**FOR**

**PMI MODEL NUMBER: RFDD-618-730049**

**FILTER DETECTOR**



DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

## TABLE OF CONTENTS

PARA	DESCRIPTION	PAGE
1.0	SCOPE	4
2.0	TEST EQUIPMENT	4
3.0	GROUP A TESTS ( 100 % ACCEPTANCE TESTS )	
3.1	VISUAL AND MECHANICAL INSPECTION	4
3.2	FREQUENCY RANGE	4
3.3	RETURN LOSS or VSWR	5
3.4	FILTER REJECTION	5
3.5	VOLTAGE SENSITIVITY	5
3.6	BARRIER POTENTIAL	5
3.7	OPERATING INPUT DYNAMIC RANGE	6
3.8	FREQUENCY RESPONSE FLATNESS	6
3.9	TRACKING	6
4.0	GROUP B TESTS ( SAMPLING TESTS )	7
4.1	LOW TEMPERATURE OPERATION	7
4.2	HIGH TEMPERATURE OPERATION	7
4.3	RESISTANCE TO SOLVENTS	7
4.4	WATER VAPOUR CONTENT	7
4.5	MAXIMUM RF INPUT POWER	7
4.6	DIODE VOLTAGE PROTECTION	7
4.7	VIDEO BYPASS CAPACITOR	7
4.8	WARM UP TIME	7
Figure 1	Network Analyzer and Log Amplifier with bias current source	8
Figure 2	DC Bias and voltmeters	9
Figure 3	RF Signal Generator and Oscilloscope	10
Figure 4	RF Signal Generator and Voltmeter	11



DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

### 1.0 SCOPE

This procedure defines the tests required for acceptance of a PMI Model RFFD-618-730049 FILTER DETECTOR. This acceptance test procedure to be used together with MIKES RF, FILTER DETECTOR ASSY drawing number 730049.

In the event of a discrepancy ALL SPECIFICATIONS VALUES in that document take priority over those within this document.

### 2.0 TEST EQUIPMENT

Item Number	ITEM	MANUFACTURER	MODEL NUMBER
1	Network Analyzer	Agilent	8722D
2	Multi-meter	HP	34401A
3	Power Supply	Agilent	3631A
4	Log Amplifier with Bias and offset cancelation	AMC custom designed test equipment	Custom test equipment
5	Oscilloscope	Tektronix	TDS3054/TDS3014B
6	RF Signal Generator	Gigatronics	12000A Microwave Synthesizer

### 3.0 GROUP A INSPECTION ( 100 % ACCEPTANCE TESTS )

3.1	VISUAL AND MECHANICAL INSPECTION	Ref -730049	3.2.2
3.1.1	Ensure the outline is in accordance with Figure1 of dwg	Ref -730049	3.3.1
3.1.2	Ensure the weight is in accordance with.	Ref -730049	3.3.2
3.1.3	Ensure the unit is marked with ESD symbol	Ref -730049	3.3.3
3.1.4	Ensure the workmanship is in accordance with	Ref -730049	3.3.4
3.1.5	Ensure the marking is in accordance with	Ref -730049	3.4.7
3.1.6	Ensure the connectors are in accordance with	Ref -730049	3.6.14
3.2	FREQUENCY RANGE	Ref -730049	3.2.1



- 3.2.1 The Detection frequency range shall be 6 GHz to 18 GHz minimum.
- 3.2.2 Detector output measurements to be carried out over this frequency range.
  
- 3.3 RETURN LOSS or VSWR Ref -730049 3.2.2
  - 3.3.1 Connect device under test (DUT) as illustrated in Figure 1.
  - 3.3.2 Ensure the network analyzer is calibrated to measure return loss over at least the specified frequency range.
  - 3.3.3 RECORD worst case return loss over specified frequency range.
  
- 3.4 FILTER REJECTION Ref -730049 3.2.4
  - 3.4.1 Connect device under test (DUT) as illustrated in Figure 1.
  - 3.4.2 Ensure that a calibration is used to identify when the log amplifier is indicating a level corresponding to the specified filter rejection. A calibration may be obtained by reducing the RF source power by an amount corresponding to the filter rejection specification and recording the passband detection level. Once the source power is returned to the original level, the filter rejection level can be compared to the recorded level.
  - 3.4.3 VERIFY or RECORD that the detector output as measured on the log amplifier is below the specified rejection level over the specified rejection frequency band.
  
- 3.5 VOLTAGE SENSITIVITY Ref -730049 3.2.5
  - 3.5.1 Connect device under test (DUT) as illustrated in Figure 3 with bias resistor of 10 k ohms.
  - 3.5.2 Ensure a calibrated signal level of -3dBm is available from the signal generator.
  - 3.5.3 Set signal generator internal pulse modulator to give 10 kHz square wave modulation of the RF signal.
  - 3.5.4 RECORD peak to peak detected voltage as measured by the oscilloscope.
  
- 3.6 BARRIER POTENTIAL Ref -730049 3.2.6
  - 3.6.1 Connect device under test (DUT) as illustrated in Figure 2.
  - 3.6.2 Set power supply to appropriate voltage to give 100 microamps bias into detector and balance diodes. If the series resistor is 10 k ohms then power supply voltage should be 1.0 volt more than diode voltage. If the series resistor is 20 k ohms then the power supply should be 2.0 volt more than diode voltage.



- 3.6.3 RECORD the voltage on the detector and balance diodes while biased at 100 micro amps.
- 3.7 OPERATING INPUT DYNAMIC RANGE Ref -730049 3.2.7
- 3.7.1 Connect device under test (DUT) as illustrated in Figure 4.
- 3.7.2 Set power supply to appropriate voltage to give 100 microamps bias into detector diode. If the series resistor is 10 k ohms then power supply voltage should be 1.0 volt more than diode voltage. If the series resistor is 20 k ohms then the power supply should be 2.0 volt more than diode voltage.
- 3.7.3 RECORD detector voltage with RF power off.
- 3.7.4 RECORD detector voltage with RF power set to -23 dBm at 12 GHz.
- 3.7.5 RECORD detector voltage with RF power set to +7 dBm at 12 GHz.
- 3.7.6 RECORD detector voltage with RF power set to +8 dBm at 12 GHz.
- 3.7.7 The detector generates negative output voltage. Progressive increments in the negative direction as the RF power is changed from off, minimum power, maximum power to beyond maximum power indicates the detector is functioning over the specified dynamic range.
- 3.8 FREQUENCY RESPONSE FLATNESS Ref -730049 3.2.8
- 3.8.1 Connect device under test (DUT) as illustrated in Figure 1.
- 3.8.2 Ensure that a calibration is used to identify when the log amplifier is indicating a level corresponding to the specified filter rejection. A calibration may be obtained by changing the RF source power by an amount equal to the peak to peak flatness specification. Recording the log amplifier output at maximum and minimum levels. The RF source power should then be adjusted to centralize the passband response between these levels. If the passband frequency response is between these levels then the unit meets specification. Alternatively the RF power may be adjusted up and down to bring the maximum and minimum points on the frequency response curve to an arbitrary reference level. The difference between these levels is the peak to peak frequency response deviation or flatness.
- 3.8.3 VERIFY or RECORD that the detector output as measured on the log amplifier and within the passband frequency range is within the specified flatness specification.
- 3.9 TRACKING Ref -730049 3.2.11
- 3.9.1 Connect device under test (DUT) as illustrated in Figure 2.
- 3.9.2 Set power supply to appropriate voltage to give 100 microamps bias into detector and balance diodes. If the series resistor is 10 k ohms then power supply voltage should be 1.0 volt more than diode voltage. If the series resistor is 20 k ohms then the power supply should be 2.0 volt more than diode voltage.



**DRAWING No: 140-R000-000**

**PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029**

**URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:**

**ISO 9001:2000 CERTIFIED**

- 3.9.3 RECORD the voltage on the detector and balance diodes while biased at 100 micro amps.
- 3.9.4 CALCULATE the difference between the detector and balance diode voltages. The difference should be less than the specified value. ( 20 mV )

#### **4.0 GROUP B INSPECTION ( SAMPLING TESTS)**

- 4.1 LOW TEMPERATURE OPERATION Ref -730049 3.5.1.1
  - 4.1.1 Perform GROUP A tests at -54 deg C
  
- 4.2 HIGH TEMPERATURE OPERATION Ref -730049 3.5.1.1
  - 4.2.1 Perform GROUP A tests at -95 deg C
  
- 4.3 RESISTANCE TO SOLVENTS Ref -730049 4.6.5.6
  - 4.3.1 Perform GROUP A tests at -95 deg C
  - 4.3.2 Electrical rejects or dummy units may be used for this test.
  
- 4.4 WATER VAPOUR CONTENT Ref -730049 4.6.5.7
  - 4.4.1 Perform GROUP A tests at -95 deg C
  - 4.4.2 Electrical rejects or dummy units may be used for this test.
  
- 4.5 MAXIMUM RF INPUT POWER Ref -730049 3.2.3
  - 4.5.1 Perform this test at -54, 25 and 95 deg C
  - 4.5.2 Apply 20 dBm at any frequency between 6 and 18 GHz to RF input for 30 seconds.
  - 4.5.3 Verify no damage or degradation by repeating Voltage Sensitivity test and ensuring no change. ( Ref -730049 3.2.5 )
  
- 4.6 DIODE VOLTAGE PROTECTION Ref -730049 3.2.9
  - 4.6.1 Perform this test at -54, 25 and 95 deg C
  
- 4.7 VIDEO BYPASS CAPACITOR Ref -730049 3.2.12
  - 4.7.1 Perform this test at 25 deg C
  - 4.7.2 THIS TEST IS OMMITTED.
  - 4.7.3 The schottky detector diode interacts with the capacitance measurements to give incorrect



**DRAWING No: 140-R000-000**

**PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029**

**URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:**

**ISO 9001:2000 CERTIFIED**

---

readings. The actual capacitors used for video bypass can be verified by design data.

- 4.8      WARM UP TIME      Ref -730049      3.2.9
- 4.8.1    Perform this test at -54.
- 4.8.2    There are no active components and no warm up occurs. TEST OMMITTED.






DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

**FIGURE 1**






DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

**FIGURE 2**



Series Resistors of 10 kohm will give 100 microamp when power supply is 1 volt above the diode voltage. Typically 1.3Volts




DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

**FIGURE 3**






DRAWING No: 140-R000-000

PLANAR MONOLITHICS INDUSTRIES, INC.  
7311-G GROVE RD., FREDERICK MD.21704  
SALES@PLANARMONOLITHICS.COM  
TEL: 301-631-1579 FAX: 301-662-2029

URL: WWW.PLANARMONOLITHICS.COM  
E-MAIL:

ISO 9001:2000 CERTIFIED

**FIGURE 4**



Series Resistors of 10 kohm will give 100 microamp when power supply is 1 volt above the diode voltage. Typically 1.3Volts