



SUMMARY TEST DATA ON DTA-2G18G-60-12-CD-1-20DBM-TS

Customer: _____
 Job No: _____
 Model No: DTA-2G18G-60-12-CD-1-20DBM-TS
 Serial No: PL26326/1933

Tested By: K. Mansfield
 Date: Friday, August 30, 2019
 Temperature: +25° C
 Drawing No: 27617795 Rev: A2

TEST. ITEM NO	PARAMETERS	SPECIFIED VALUE	PASS/FAIL	QA QC	
1	Frequency Range:	2 GHz – 18 GHz	2 GHz – 18 GHz	PMI QA 1	
2	Insertion Loss:	4.8 dB Max.	3.6 dB See Plot		
3	VSWR:	2.0:1 Max.	1.68:1 See Plot		
4	Flatness to 20 dB:	± 1.0 dB Typ.	0.37 dB See Plot		
6	Flatness to 40 dB:	± 1.25 dB Typ.	0.67 dB See Plot		
7	Flatness to 60 dB:	± 3.0 dB Typ.	1.87 dB See Plot		
8	Accuracy of Attenuation 0 to 20 dB:	± 1.0 dB Typ.	0.03 dB See Plot		
9	Accuracy of Attenuation 20 to 40 dB:	± 1.5 dB Typ.	0.11 dB See Plot		
10	Accuracy of Attenuation 40 to 60 dB:	± 2.0 dB Typ.	0.14 dB See Plot		
11	Temp. Sensor:	10mV/°C, 3.0V @ 25°C	2.97V		
12	Switching Speed:	On Time: 1.0 µs Max. Off Time: 0.5 µs Max.	<1.0 µs On Time <0.5 µs Off Time See Typical Characteristics		
13	DC Supply:	+15VDC @ 150 mA Max.	117 mA		PMI QA 1

Programed Attenuation	Attenuation	Accuracy of Attenuation	Flatness dB
dB	dB	dB	±dB
0.0156	0.0124	0.00	0.00
0.0313	0.0266	0.00	0.00
0.0625	0.06	0.00	0.00
0.125	0.12	0.01	0.01
0.25	0.25	0.00	0.01
0.50	0.50	0.00	0.03
1.00	1.00	0.00	0.05
2.00	2.01	-0.01	0.12
4.00	4.02	-0.02	0.22
8.00	8.03	-0.03	0.32
16.00	16.01	0.01	0.32
32.00	31.99	0.01	0.61

Programed Attenuation	Attenuation	Accuracy of Attenuation	Flatness dB
dB	dB	dB	±dB
5.00	4.98	0.02	0.26
10.00	10.03	-0.03	0.33
15.00	14.99	0.01	0.33
20.00	20.01	-0.01	0.37
25.00	24.94	0.06	0.51
30.00	29.97	0.03	0.60
35.00	34.89	0.11	0.64
40.00	39.94	0.06	0.67
45.00	44.86	0.14	0.64
50.00	49.89	0.11	1.01
55.00	54.88	0.12	1.35
60.00	59.87	0.13	1.87

QA/QC Approval: PMI QA 1

Date: 8/30/19



SUMMARY TEST DATA ON DTA-2G18G-60-12-CD-1-20DBM-TS

PL26326/1933

